

Eagle Mine
Humboldt Mill Effluent (HME)
October 2014 Results

Date	Location	Parameter	CEMP Results	Eagle Results	Monthly Limit	Units
10/1/2014	HME	Antimony	3.2	3.7	-	ug/L
10/1/2014	HME	Arsenic	<1.0	<1.0	150	ug/L
10/1/2014	HME	Barium	4.8	<5.0	-	ug/L
10/1/2014	HME	BOD	-	<2.0		
10/1/2014	HME	Boron	67	59	-	ug/L
10/1/2014	HME	Cadmium	<1.0	<0.20	6	ug/L
10/1/2014	HME	Chromium	<0.9	<1.0	-	ug/L
10/1/2014	HME	Cobalt	<2.0	1.8	100	ug/L
10/1/2014	HME	Copper	<1.0	<1.0	19	ug/L
10/1/2014	HME	Fluoride	0.1	0.19	-	mg/L
10/1/2014	HME	Hardness	-	211		
10/1/2014	HME	Lead	<1.0	<1.0	73	ug/L
10/1/2014	HME	Lithium	2.8	<8.0	-	ug/L
10/1/2014	HME	Manganese	26	26	2800	ug/L
10/1/2014	HME	Mercury	<0.500	<0.500	1.3	ng/L
10/1/2014	HME	Molybdenum	8	<25	-	ug/L
10/1/2014	HME	Nickel	1.2	<2.0	82	ug/L
10/1/2014	HME	Nitrogen, Ammonia	<0.1	<0.050	-	mg/L
10/1/2014	HME	Phosphorus	0.07	0.0109	1	mg/L
10/1/2014	HME	Selenium	<2.0	<1.0	5	ug/L
10/1/2014	HME	Solids, Dissolved	360	350	-	mg/L
10/1/2014	HME	Solids, Suspended	<10	<3.3	20	mg/L
10/1/2014	HME	Strontium	180	170	-	ug/L
10/1/2014	HME	Sulfate	130	130	-	mg/L
10/1/2014	HME	Zinc	<5.0	<10	360	ug/L