

Eagle Mine
Humboldt Mill Water Treatment Plant Effluent
May 2015 Results

| Sample Date | Location | Parameter | CEMP Result | Eagle Result | Monthly Limit | Units |
|-------------|------------------|-----------------------------|-------------|--------------|---------------|-------|
| 5/6/2015 | Hum-WTP Effluent | Antimony | 3.3 | 3.4 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Arsenic | | < 0.006 | < 1.0 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Barium | 9.5 | 9.6 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | BOD, (5-Day) | | < 2.0 | - | mg/L |
| 5/6/2015 | Hum-WTP Effluent | Boron | 70 | 60 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Cadmium | | < 0.20 | 6 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Chromium | < 0.9 | < 1.0 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Cobalt | | 2 | 100 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Copper | | < 1.0 | 19 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Fluoride | | 130 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Lead | | < 1.0 | 73 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Lithium | 3.4 | < 8.0 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Manganese | | 390 | 2800 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Mercury | < 0.1 | < 0.5 | 1.3 | ng/L |
| 5/6/2015 | Hum-WTP Effluent | Molybdenum | 7.5 | < 25 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Nickel | | 2.8 | 82 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Nitrogen, Ammonia | < 0.1 | 0.055 | - | mg/L |
| 5/6/2015 | Hum-WTP Effluent | Phosphorus | | < 0.1 | 1 | mg/L |
| 5/6/2015 | Hum-WTP Effluent | Residue, Dissolved @ 180° C | | 330 | - | mg/L |
| 5/6/2015 | Hum-WTP Effluent | Residue, Suspended | | < 3.3 | 20 | mg/L |
| 5/6/2015 | Hum-WTP Effluent | Selenium | | < 1.0 | 5 | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Strontium | 190 | 190 | - | ug/L |
| 5/6/2015 | Hum-WTP Effluent | Sulfate | | 120 | - | mg/L |
| 5/6/2015 | Hum-WTP Effluent | Zinc | | < 10 | 360 | ug/L |